

06420/06421/06425/06426/06440/06441/06445/06446.2312 (23 mm orifice) [91202] [Safety Relief Valve]
 06420/06421/06425/06426/06440/06441/06445/06446.2312 (23 mm orifice)
 Capacity Tests: Sec. VIII Div. 1 at National Board Testing Lab on February 27, 2015
 Method of Establishing Relieving Capacity: Flow Capacity, Slope
 Certified Value: 6.510 SCFM/PSIA
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Fixed
 Designed by: HEROSE GMBH Armaturen Und Metalle {HEG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Code Section
1.25 NPS	1.5 NPS	415,5	23 mm	6 mm	20-145 psi	Air	VIII Div. 1

Manufacturer/Assembler	Code Sections	Expiration Date
HEROSE GMBH Armaturen Und Metalle (HEG) Bad Oldesloe, 23843 Germany	VIII Div. 1	05.27.2027